

Island County Water Well Information



WellKey: 348

General Information

Owner Name (log): Jerry Squire

DOE Tag: AKY792

DOE NOI:

DOE ID

79648

Well Address: E 1/2 NW 1/4 NW 1/4 NE 1/4

Well Parcel: [R23118-464-3370](#)

Served Parcel:

Horiz/Vert Accuracy: Site Plan / DEM

Site Type: Well

SWI Rating: Low Risk



Construction Information

Construction Date: 04/22/87

Driller Name: Well Done Drillers

LS Elevation: 316 ft. MSL

Depth Well: 350 ft.

TD Elevation: -34 ft. MSL

WL Measurements: [1 measurement \(Click to View\)](#)

WL Elevation: 7 ft. MSL



Water Quality Information

Water Samples: [8 samples \(Click to View\)](#)


Avg/Med/Max Arsenic: 0.006 / 0.006 / 0.007 mg/l

Avg/Med/Max Chloride: 31.30 / 37.6 / 40 mg/l

Avg/Med/Max Hardness: 176.50 / 176.5 / 190 mg/l

Avg/Med/Max Nitrate: 0.15 / 0.1 / 0.25 mg/l

Bacteria Samps (distribution): [17 samples \(Click to View\)](#)



Public Water System Information


Pws Name: Squires Well

PwsID: [46897](#)

Approved Connects: 14

Pws Source #: SO# 1

Pws Source Name: Well #1 AKY792



Note: Underlined items in **bright blue** are hyperlinks to additional information / resources.
Questions? Contact the [Island County Hydrogeologist](#), or visit the [Hydrogeology Web Page](#).

Report Generated: 12/30/2020